



# Certificate of Compliance

Certificate: 1088089 (LR 30024)

Master Contract: 168560

Project: 70011632

Date Issued: December 11, 2014

Issued to: Echo Electric Company Limited  
621 Nagai Yatsushiro-cho  
Fuefuki-shi, Yamanashi 406-0823  
Japan  
Attention: Toshio Masuda

*The products listed below are eligible to bear the CSA Mark shown*



*Zhibin Li*

Issued by: Zhibin Li

## PRODUCTS

**CLASS 6225 01 - FUSEHOLDER ASSEMBLIES**

Fuseholder assemblies, extractor type, intended for panel mounting, Models FH043 and FH033, rated 10 A, 250 V ac.

Notes:

1. The fuseholders are certified for use only as component parts of equipment where the acceptability of the combination is determined by the CSA International.
2. The fuseholders are certified for use with 5.2 mm by 20 mm fuses only.

## APPLICABLE REQUIREMENTS

CSA Standard C22.2 No.39 - Fuseholder assemblies

Edition 1: March 9, 1988; Application No LR 30024-19 - Rexdale  
Issued by S. Jeffery, C.E.T. Reviewed by C. Law, P. Eng.

Contents: Pages - 1 to 4

SUBJECT

CLASS 6225 01 - FUSEHOLDER ASSEMBLIES

Fuseholder assemblies, extractor type, intended for panel mounting, examination of model nos FH002, FH032, FH042, FH-S07, FH-S11, FH-B01, FH-S10, FH033, FH043, FH-B02, FH-508 & FH-S09 to the requirements of Electrical Certification Notice 552.

Note: These fuseholders are intended for use only as component parts of equipment where the acceptability of the combination has been determined by the Canadian Standards Association.

B356/1/c1

It is the Submitter's responsibility to ensure that the CSA Mark is applied to this product only when the product complies with this report.