



Certificate of Compliance

Certificate: 1088092 (LR 30024)

Master Contract: 168560

Project: 70011637

Date Issued: December 11, 2014

Issued to: Echo Electric Company Limited
621 Nagai Yatsushiro-cho
Fuefuki-shi, Yamanashi 406-0823
Japan
Attention: Toshio Masuda

The products listed below are eligible to bear the CSA Mark shown



Zhibin Li

Issued by: Zhibin Li, P. Eng.

PRODUCTS

CLASS 6225 01 - FUSEHOLDER ASSEMBLIES

Fuseholder assemblies, Model FH-B12, extractor type, for panel mounting, rated 10 A, 250 V ac, for use with 5.2 mm by 20 mm fuses.

Notes:

These fuseholders are certified as components for use only with other certified equipment where the suitability of the combination is determined by CSA Group.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 39 - Fuseholder Assemblies