



# Certificate of Compliance

Certificate: 70011626 (LR 30024-15)

Master Contract: 168560

Project: 70011626

Date Issued: December 11, 2014

Issued to: Echo Electric Company Limited  
621 Nagai Yatsushiro-cho  
Fuefuki-shi, Yamanashi 406-0823  
Japan  
Attention: Toshio Masuda

*The products listed below are eligible to bear the CSA Mark shown*



*Zhibin Li*

Issued by: Zhibin Li

## **PRODUCTS**

### **CLASS 6225 01 - FUSEHOLDER ASSEMBLIES**

Fuseholder assemblies, extractor type, for panel mounting, 250V ac and less, Model FH-S07, 10A and less, FH-S11, 10A and less, FH-S10, 15A and less, for use with 1/4 in by 1-1/4 in fuses, Model FH-S08, 10A and less, Model FH-S09, 6A and less, for use with 5.2mm by 20mm fuses.

#### Note:

These fuseholders are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by the Canadian Standards Association.

## **APPLICABLE REQUIREMENTS**

C22.2 No.39 - Fuseholder Assemblies

Edition 1: March 9, 1988; Application No LR 30024-19 - Rexdale  
Issued by S. Jeffery, C.E.T. Reviewed by C. Law, P. Eng.

Contents: Pages - 1 to 4

SUBJECT

CLASS 6225 01 - FUSEHOLDER ASSEMBLIES

Fuseholder assemblies, extractor type, intended for panel mounting, examination of model nos FH002, FH032, FH042, FH-S07, FH-S11, FH-B01, FH-S10, FH033, FH043, FH-B02, FH-508 & FH-S09 to the requirements of Electrical Certification Notice 552.

Note: These fuseholders are intended for use only as component parts of equipment where the acceptability of the combination has been determined by the Canadian Standards Association.

B356/1/c1

It is the Submitter's responsibility to ensure that the CSA Mark is applied to this product only when the product complies with this report.