



Certificate of Compliance

Certificate: 1360544 (LR 30024)

Master Contract: 168560

Project: 70011629

Date Issued: December 11, 2014

Issued to: Echo Electric Company Limited
621 Nagai Yatsushiro-cho
Fuefuki-shi, Yamanashi 406-0823
Japan
Attention: Toshio Masuda

The products listed below are eligible to bear the CSA Mark shown



Zhibin Li

Issued by: Zhibin Li

PRODUCTS

CLASS 6225 01 - FUSEHOLDER ASSEMBLIES

Fuseholder assemblies, extractor type, intended for panel mounting, Model FH-S07F, rated 15A, 250V ac.

Note:

1. These fuseholders are certified as components for use only with other certified equipment where the suitability of the combination is determined by CSA Group.
2. These fuseholders are certified for use with Certified 1-1/4 in long by 1/4 in Dia fuse only.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No.39 - Fuseholder Assemblies

E.C.N.No.552b (November 23, 1989) - Postponement of the Effective Date for Clause 4.1.1, 4.5.5 and 6.6 of CSA C22.2 No.39-M1987 Fuseholder Assemblies